

**EVALUATION REPORT OF  
UNION CORRUGATING COMPANY  
'29 GA. 5V PANEL'**


**FLORIDA PRODUCT APPROVAL  
FL 7271.3-R2  
ROOFING  
METAL ROOFING**

**Prepared For:  
Union Corrugating Company  
P. O. Box 229  
Fayetteville, NC 28302  
Telephone: (910) 483-0479  
Fax: (910) 483-8897**

**Prepared By:  
Bala Sockalingam, Ph.D., P.E.  
Florida Professional Engineer #62240  
1216 N Lansing Ave., Suite C  
Tulsa, OK 74106  
Telephone: (918) 492-5992  
FAX: (866) 366-1543**

**This report consists of  
Evaluation Report (2 Pages including cover)  
Installation Details (2 Pages)**

**Report No. C1805-11  
Date: 11.30.11**



Manufacturer: Union Corrugating Company

Product Name: 5V Panel

Panel Description: 24" wide coverage with (5) 1/2" high ribs

Materials: Minimum 29 ga., 80 ksi steel. Galvanized coated steel (ASTM A653) or Galvalume coated steel (ASTM A792) or painted steel (ASTM A755).

Deck Description: Min 15/32" thick plywood or 7/16" thick OSB for new and existing constructions. Designed and installed as per FBC 2010.

Deck Attachment: 8d x 2.5" long ring shank nails or #8 x 2" long wood screws @ 6" o.c. at plywood field and edges.

Underlayment: Minimum underlayment as per FBC 2010 Section 1507.4.5

Slope: 1/2:12 or greater in accordance with FBC 2010 Section 1507.4.2

Design Uplift Pressure: 52.5 psf @ fastener spacing of 12" o.c.  
(Factor of Safety = 2)

Panel Attachment: #9-15 x 1.5" wood screw with washer  
At panel ends @ max 6" o.c. across panel width through panel flat  
At interior @ max 12" o.c. across panel width through panel flat

Test Standards: Roof assembly tested in accordance with UL580-94 'Uplift Resistance of Roof Assemblies' and FM 4470 Section 5.5 'Resistance to Foot Traffic'.

Code Compliance: The product described herein has demonstrated compliance with FBC 2010 Section 1507.4

Product Limitations: Design wind loads shall be determined for each project in accordance with FBC 2010 Section 1609 or ASCE 7-10 using allowable stress design. The maximum fastener spacing listed herein shall not be exceeded. This product is not approved for use in the High Velocity Hurricane Zone. Fire classification is not within scope of this Evaluation Report. Refer to FBC 2010 Section 1505 and current approved roofing materials directory or ASTM E108/UL790 report from an accredited laboratory for fire ratings of this product.

Supporting Documents: UL580 Roof Deck Construction No. 579  
  
FM 4470 Test Report  
ENCON Technology Inc  
C1583-3, Reporting Date 7/24/08

## Construction No. 579 TGKX.579 Roof Deck Constructions

[Page Bottom](#)

### Design/System/Construction/Assembly Usage Disclaimer

- Authorities Having Jurisdiction should be consulted in all cases as to the particular requirements covering the installation and use of UL Listed or Classified products, equipment, system, devices, and materials.
- Authorities Having Jurisdiction should be consulted before construction.
- Fire resistance assemblies and products are developed by the design submitter and have been investigated by UL for compliance with applicable requirements. The published information cannot always address every construction nuance encountered in the field.
- When field issues arise, it is recommended the first contact for assistance be the technical service staff provided by the product manufacturer noted for the design. Users of fire resistance assemblies are advised to consult the general Guide Information for each product category and each group of assemblies. The Guide Information includes specifics concerning alternate materials and alternate methods of construction.
- Only products which bear UL's Mark are considered as Classified, Listed, or Recognized.

### Roof Deck Constructions


[See General Information for Roof Deck Constructions](#)

#### Construction No. 579

January 08, 2009

**Uplift — Class 90**

**Fire Not Investigated**



1. **Metal Roof Deck Panels\*** — No. 29 MSG min thick coated steel. 24 in. cover width (26 in. overall width).

**AMERICAN CONSTRUCTION METALS** ([View Classification](#)) — "5V Crimp"

**MARLYN METALS INC** ([View Classification](#)) — "5V CRIMP"

**METAL SALES MFG CORP** ([View Classification](#)) — "5V- Crimp"

**UNION CORRUGATING CO** ([View Classification](#)) — "5-V"

**WHEELING-PITTSBURGH STEEL CORP, DIV**

**OF WHEELING CORRUGATING CO** ([View Classification](#)) — "5V"

2. **Fasteners (Screws)** — Fasteners to attach the plywood deck to the joists to be 2 in. long, No. 8 coarse thread screws. Fasteners to attach the panels to the deck to be No. 9-15 x 1-1/2 in. long sharp point screws with a hex-washer head. Fasteners to be spaced a maximum of 12 in. OC along one side of each rib.

3. **Deck** — Min 7/16 in. thick APA rated oriented strand board or min 15/32 in. thick, Type C-D, APA rated plywood.

4. **Underlayment** — 30 lb. felt, min 2 in. sidelap, attached per manufacturer's recommendations.

5. **Joists** — Graded dimension lumber, No. 2 or better. Spaced a max of 24 in. OC.

Refer to general information, Roof Deck Construction, for Items not evaluated.

\*Bearing the UL Classification Mark

Last Updated on 2009-01-08

[Questions?](#)

[Print this page](#)

[Notice of Disclaimer](#)

[Page Top](#)

[Copyright © 2011 Underwriters Laboratories Inc.®](#)

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2011 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.

