

**EVALUATION REPORT OF
UNION CORRUGATING COMPANY
'29 GA. MASTERRIB PANEL'**


**FLORIDA PRODUCT APPROVAL
FL 7271.8-R2
ROOFING
METAL ROOFING**

**Prepared For:
Union Corrugating Company
P. O. Box 229
Fayetteville, NC 28302
Telephone: (910) 483-0479
Fax: (910) 483-8897**

**Prepared By:
Bala Sockalingam, Ph.D., P.E.
Florida Professional Engineer #62240
1216 N Lansing Ave., Suite C
Tulsa, OK 74106
Telephone: (918) 492-5992
FAX: (866) 366-1543**

**This report consists of
Evaluation Report (2 Pages including cover)
Installation Details (2 Pages)**

**Report No. C1805-16
Date: 11.30.11**



Manufacturer: Union Corrugating Company

Product Name: MasterRib Panel

Panel Description: 36" wide coverage with 3/4" high ribs at 9" o.c.

Materials: Minimum 29 ga., 80 ksi steel. Galvanized coated steel (ASTM A653) or Galvalume coated steel (ASTM A792) or painted steel (ASTM A755).

Deck Description: Min 15/32" thick plywood or 7/16" thick OSB for new and existing constructions. Designed and installed as per FBC 2010.

Deck Attachment: 8d x 2.5" long ring shank nails or #8 x 2" long wood screws @ 6" o.c. at plywood field and edges.

Underlayment: Minimum underlayment as per FBC 2010 Section 1507.4.5

Slope: 1/2:12 or greater in accordance with FBC 2010 Section 1507.4.2

Design Uplift Pressure: 52.5 psf @ fastener spacing of 12" o.c.
(Factor of Safety = 2)

Panel Attachment: #9-15 x 1" wood screw with washer
At panel ends @ 5.5"-3.5"-5.5" o.c. across panel width
At intermediate @ 9" o.c. across panel width with 2 screws at panel overlap

Test Standards: Roof assembly tested in accordance with UL580-94 'Uplift Resistance of Roof Assemblies' and FM 4470 Section 5.5 'Resistance to Foot Traffic'.

Code Compliance: The product described herein has demonstrated compliance with FBC 2010 Section 1507.4

Product Limitations: Design wind loads shall be determined for each project in accordance with FBC 2010 Section 1609 or ASCE 7-10 using allowable stress design. The maximum fastener spacing listed herein shall not be exceeded. This product is not approved for use in the High Velocity Hurricane Zone. Fire classification is not within scope of this Evaluation Report. Refer to FBC 2010 Section 1505 and current approved roofing materials directory or ASTM E108/UL790 report from an accredited laboratory for fire ratings of this product.

Supporting Documents: UL580 Roof Deck Construction No. 584

FM 4470 Test Report
ENCON Technology Inc
C1583-2, Reporting Date 7/24/08

Construction No. 584 TGKX.584 Roof Deck Constructions

[Page Bottom](#)

Design/System/Construction/Assembly Usage Disclaimer

- Authorities Having Jurisdiction should be consulted in all cases as to the particular requirements covering the installation and use of UL Listed or Classified products, equipment, system, devices, and materials.
- Authorities Having Jurisdiction should be consulted before construction.
- Fire resistance assemblies and products are developed by the design submitter and have been investigated by UL for compliance with applicable requirements. The published information cannot always address every construction nuance encountered in the field.
- When field issues arise, it is recommended the first contact for assistance be the technical service staff provided by the product manufacturer noted for the design. Users of fire resistance assemblies are advised to consult the general Guide Information for each product category and each group of assemblies. The Guide Information includes specifics concerning alternate materials and alternate methods of construction.
- Only products which bear UL's Mark are considered as Classified, Listed, or Recognized.

Roof Deck Constructions


[See General Information for Roof Deck Constructions](#)

Construction No. 584

September 22, 2011

Uplift — Class 90

Fire Not Investigated



1. **Metal Roof Deck Panels*** — No. 29 MSG min. thick coated steel. 36 in. wide (cover width).

ALL STEEL BUILDINGS & COMPONENTS

TUBULAR DIVISION INC ([View Classification](#)) — "Master-Rib"

AMERICAN CONSTRUCTION METALS ([View Classification](#)) — "Perfect Rib"

DAVISS COUNTY METAL SALES INC ([View Classification](#)) — "D.C. Rib"

CENTRAL STATES MFG INC ([View Classification](#)) — "Panel-Loc Plus"

FABRAL INC ([View Classification](#)) — "Grandrib 3"

FE SAWYER BUILDING SYSTEMS INC, DBA

SAWYER METAL ([View Classification](#)) — "Tex-Rib"

GIDEON STEEL PANEL CO ([View Classification](#)) — "Gideon Tuff-Rib AG"

IDEAL ROOFING CO LTD ([View Classification](#)) — "AMERI-CANA™"

MARLYN METALS INC ([View Classification](#)) — "Mar-Rib"

METAL SALES MFG CORP ([View Classification](#)) — "Classic Rib"

UNION CORRUGATING CO ([View Classification](#)) — "Master-Rib Panel"

WHEELING-PITTSBURGH STEEL CORP, DIV

OF WHEELING CORRUGATING CO ([View Classification](#)) — "CenturyDrain"

2. **Fasteners Screws** — Fasteners used to attach the plywood deck to the joists to be 2 in. long, No. 8 coarse thread screws. Fasteners to be spaced 6 in. OC at the plywood joists over supports and 12 in. OC in the field of the plywood. Fasteners used to attach the panels to the deck to be No. 9-15 x 1 in. long sharp point screws with a hex-washer head and sealing washer. Fasteners to be spaced a maximum of 12 in. OC along one side of each rib except at panel overlap locations where fasteners are to be spaced 12. in OC and located on both sides of the lap.

3. **Deck** — Min 15/32 in. thick, Type C-D, APA rated plywood or minimum 7/16 in. thick oriented strand board.

4. **Underlayment** — Min. Type 15 asphalt saturated felt, min. 2 in. sidelap, attached per manufacturer's recommendations.

5. **Joists** — Graded dimension lumber, No. 2 or better. Spaced a maximum of 24 in. OC.

*Bearing the UL Classification Mark

[Last Updated](#) on 2011-09-22

[Questions?](#)

[Print this page](#)

[Notice of Disclaimer](#)

[Page Top](#)

[Copyright © 2011 Underwriters Laboratories Inc.®](#)

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2011 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.

