

**EVALUATION REPORT OF  
UNION CORRUGATING COMPANY  
'26 GA. PBR PANEL'**


**FLORIDA PRODUCT APPROVAL  
FL 7271.11-R2  
ROOFING  
METAL ROOFING**

**Prepared For:  
Union Corrugating Company  
P. O. Box 229  
Fayetteville, NC 28302  
Telephone: (910) 483-0479  
Fax: (910) 483-8897**

**Prepared By:  
Bala Sockalingam, Ph.D., P.E.  
Florida Professional Engineer #62240  
1216 N Lansing Ave., Suite C  
Tulsa, OK 74106  
Telephone: (918) 492-5992  
FAX: (866) 366-1543**

**This report consists of  
Evaluation Report (2 Pages including cover)  
Installation Details (2 Pages)**

**Report No. C1805-19  
Date: 11.30.11**



Manufacturer: Union Corrugating Company

Product Name: PBR Panel

Panel Description: 36" wide coverage with 1-1/4" high ribs at 12" o.c.

Materials: Minimum 26 ga., 80 ksi steel. Galvanized coated steel (ASTM A653) or Galvalume coated steel (ASTM A792) or painted steel (ASTM A755).

Deck Description: Min 19/32" thick plywood for new and existing constructions. Designed and installed as per FBC 2010.

Deck Attachment: 8d x 2.5" long ring shank nails or #8 x 2" long wood screws @ 6" o.c. at plywood field and edges.

Underlayment: Minimum underlayment as per FBC 2010 Section 1507.4.5

Slope: 1/2:12 or greater in accordance with FBC 2010 Section 1507.4.2

Design Uplift Pressure: 52.5 psf @ fastener spacing of 12" o.c.  
(Factor of Safety = 2)

Panel Attachment: #9-15 x 1.5" wood screw with washer  
At panel ends @ 7"-5"-7" o.c. across panel width  
At intermediate @ 12" o.c. across panel width

Sidelap Attachment: 1/4"-14 x 7/8" long SDS @ max 20" o.c.

Test Standards: Roof assembly tested in accordance with UL580-94 'Uplift Resistance of Roof Assemblies'.

Code Compliance: The product described herein has demonstrated compliance with FBC 2010 Section 1507.4

Product Limitations: Design wind loads shall be determined for each project in accordance with FBC 2010 Section 1609 or ASCE 7-10 using allowable stress design. The maximum fastener spacing listed herein shall not be exceeded. This product is not approved for use in the High Velocity Hurricane Zone. Fire classification is not within scope of this Evaluation Report. Refer to FBC 2010 Section 1505 and current approved roofing materials directory or ASTM E108/UL790 report from an accredited laboratory for fire ratings of this product.

Supporting Documents: UL580 Roof Deck Construction No. 638

**Construction No. 638**  
**TGKX.638**  
**Roof Deck Constructions**

[Page Bottom](#)

**Design/System/Construction/Assembly Usage Disclaimer**

- Authorities Having Jurisdiction should be consulted in all cases as to the particular requirements covering the installation and use of UL Listed or Classified products, equipment, system, devices, and materials.
- Authorities Having Jurisdiction should be consulted before construction.
- Fire resistance assemblies and products are developed by the design submitter and have been investigated by UL for compliance with applicable requirements. The published information cannot always address every construction nuance encountered in the field.
- When field issues arise, it is recommended the first contact for assistance be the technical service staff provided by the product manufacturer noted for the design. Users of fire resistance assemblies are advised to consult the general Guide Information for each product category and each group of assemblies. The Guide Information includes specifics concerning alternate materials and alternate methods of construction.
- Only products which bear UL's Mark are considered as Classified, Listed, or Recognized.

**Roof Deck Constructions**


[See General Information for Roof Deck Constructions](#)

**Construction No. 638**

March 10, 2006

**Uplift — Class 90**

**Fire Not Investigated**



1. **Metal Roof Deck Panels\*** — No. 26 MSG min gauge coated steel. Max panel width 36 in., rib height 1-1/4 in. Panels continuous over two or more spans. End laps to overlap 4 in. A bead of sealant may be used at panel end lap and side ribs.

**UNION CORRUGATING CO** ([View Classification](#)) — "PBR-Panel"

2. **Panel Fasteners (Screws)** — Fasteners used to attach panel to plywood decking (Item 4) to be #9-16 x 1-1/2 in. Hex Head wood screw with self sealing washer.

Fastener spacing for panel to deck connection to be 12 in. OC, 2-1/2 in. from center line on one side of each major rib.

Fastener 24 in. spacing at end lap to be 5-7-5-7 in. pattern, 2-1/2 in. from center line on both sides of each major rib.

2A. **Fasteners (Screws)** — Fasteners used to attach panel to panel along the sidelap to be #1/4-14 Hex Head self drilling screw with self sealing washer. Max fastener spacing to be 20 in. OC.

3. **Vapor Barrier** — (Optional) — (Not Shown) - Single ply between the substructure or plywood decking (Item 4) and panels to be min 30 lb. roofing felt.

4. **Plywood Decking** — Plywood decking to be graded per PS83 specifications, min 19/32 in. thick, exposure sheathing span C-D, 40/20 plywood. All joints to occur over supports.

5. **Supports** — Max spacing of 24 in. OC. Any of the following types may be used to support the plywood decking:

- a. Nom 2 in. by 6 in., min No. 2 grade A.F.P.A S-P-F Hemlock Fir, Douglas Fir or Southern Pine or equivalent.
- b. Wood trusses with a nom 2 in. by 4 in. upper chord of the same grade as Item a.
- c. Min No. 22 MSG cold formed coated steel purlin or bar joist (min yield to be 33,000 psi).

6. **Plywood Fasteners** — (Not Shown) - Fasteners used to attach the plywood deck to the supports to be as follows:

- a. For plywood-to-wood supports No. 8-18 by 1-7/8 in. long bugle-head steel screws with a No. 2 Phillips drive, a "Hi-Low" thread pattern and an "S-Point".
- b. As an alternate to Item a, 8d, 2 in. long galvanized ring shank nails may be used.
- c. For plywood-to-steel supports for a steel thickness less than No. 20 MSG No. 7-19 by 1-1/4 in. long bugle-head steel screws with a No. 2 Phillips head drive, a "Hi-Low" thread pattern and an "S-Point". For a steel thickness greater than No. 20 MSG to No. 16 MSG, No. 6-20 by 1-1/4 in. long bugle-head steel screws with a No. 2 Phillips drive and an S12 (TEK/3) point.

Fastener spacing for all fastener types to be 6 in. OC at the plywood edges and 12 in. OC in the interior.

Refer to general information, Roof Deck Construction, for Items not evaluated.

\*Bearing the UL Classification Mark

Last Updated on 2006-03-10

[Questions?](#)

[Print this page](#)

[Notice of Disclaimer](#)

[Page Top](#)

[Copyright © 2011 Underwriters Laboratories Inc.®](#)

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2011 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.

